

**VALIDATION REPORT No. 361823**

this document is based on test report No. 346412  
dated 31 October 2017 issued by Istituto Giordano

Customer

**NORDWALL S.r.l.**

Via Ruzzante, 14 - 35020 SANT'ANGELO DI PIOVE DI SACCO (PD) - Italy

Item\*

**non-loadbearing internal partition named  
"DUO"**

Activity

**soft and hard body impact resistance in accordance with  
ETAG 003:2012 guideline and standard  
UNI ISO 7892:1990**

Results

Test	Normative reference	Class	Result
0,5 kg hard body impact	ETAG 003:2012	III and IV	compliant
1 kg hard body impact	ETAG 003:2012	III and IV	compliant
50 kg soft body impact	ETAG 003:2012	III and IV	compliant

(\*) according to that stated by the customer.

Bellaria-Igea Marina - Italy, 31 May 2019

Chief Executive Officer

Order:  
80554Identification of item received:  
2017/2410 dated 23 October 2017Activity date:  
23 October 2017Activity site:  
Istituto Giordano S.p.A. - Strada Erbosa Uno, 72 -  
47043 Gatteo (FC) - Italy

Contents	Page
Description of item*	2
Normative references	2
Apparatus	3
Method	3
Environmental conditions	3
Results	4
Findings	5

This document is made up of 5 pages and 1 annex and shall not be reproduced except in full without extrapolating parts of interest at the discretion of the customer, with the risk of favoring an incorrect interpretation of the results, except as defined at contractual level.

The results relate only to the item examined, as received, and are valid only in the conditions in which the activity was carried out.

This document extends the validity of all numerical and descriptive data contained in the reference test report.

This document is the English translation of the validation report No. 361823 dated 31 May 2019 issued in Italian; in case of dispute the only valid version is the Italian one. Date of translation: 31 May 2019.

The original of this document consists of an electronic document digitally signed pursuant to the applicable Italian Legislation.

Chief Test Technician:

Dott. Andrea Bruschi

Head of Security and Safety Laboratory:

Dott. Andrea Bruschi

Compiler: Agostino Vasini

Reviewer: Dott. Andrea Bruschi

Page 1 of 5